

In the water loss audit submitted to the Texas Water Development Board for the time period of Jan-Dec 2022, our system lost an estimated **58,562,143 gallons** of water. If you have any questions about the water loss audit please call 713-662-8150.

#### DROUGHT CONTINGENCY AND WATER CONSERVATION PLAN

The City of Bellaire has a Drought Contingency Plan should a drought or other event occur. Here are the stages:

##### Stage 1—Annual Drought and Conservation Awareness Campaign

From May 1 through October 31 of each year, the City of Bellaire seeks to increase customer awareness of water conservation and encourage the most efficient use of water.

##### Stage 2—MILD Water Shortage Conditions

When Average Daily Water Usage reaches 65% of safe distribution capacity for three (3) consecutive days, water customers are requested to voluntarily limit the irrigation of landscaped areas to even-numbered days for customers with a street address ending in an even number, and odd-numbered days for water customers with a street address ending in an odd number, and to irrigate landscapes only between the hours of 12:00 a.m. to 3:00 a.m. and 9:00 p.m. to 12:00 a.m. on designated watering days.

##### Stage 3—MODERATE Water Shortage Conditions

When Average Daily Water Usage reaches 70% of safe distribution capacity for three (3) consecutive days, the following mandatory lawn-watering schedule shall be implemented. Customers with even numbered addresses may water on Sundays and Thursdays. Customers with odd numbered addresses may water on Saturdays and Wednesdays. Watering shall occur only between the hours of 12:00 a.m. to 3:00 a.m. and 9:00 p.m. to 12:00 a.m. on designated watering days.

##### Stage 4—SEVERE Water Shortage Conditions

When Average Daily Water Usage reaches 80% of safe distribution capacity for two (2) consecutive days, the City will ban the use of water not essential for public health or safety including: Watering lawns and shrubs, street washing, washing driveways and automobiles, water hydrant flushing, filling swimming pools, athletic field watering.

After five (5) consecutive days of water usage below the triggering factors of the Stage, the Drought Contingency Plan reverts to the previous Stage.

Some helpful tips to conserve water:

- Do not water lawns daily. (Do not overwater or allow water to run off to street; change timers on sprinklers to water after midnight.)
- Check your swimming pool to make sure it is not overfilling.
- Check for and repair detectable water leaks as soon as possible.
- Keep showers under five minutes.
- Turn water off while brushing teeth.
- Replace older-model showerheads and faucets.
- Limit washing vehicles.

Your cooperation will help ensure that water supplies are maintained at maximum levels and prevent the need to impose more restrictive measures to conserve water.

For more information, go to <https://bellairetx.gov/CCR>



# City of Bellaire

## Public Participation Opportunities:

Public input concerning the City of Bellaire water system may be made at:

4401 Edith  
Bellaire, TX  
Monday - Friday  
9:00 am - 3:00 pm  
Contact: City of Bellaire  
713-662-8150  
<https://bellairetx.gov/CCR>


### En Espanol:

Este informe incluye informacion importante sobre el agua potable. Si tiene preguntas o comentarios sobre este informe en espanol, favor de llamar al tel. 713-662-8170 para hablar con una persona bilingue en espanol.

# City of Bellaire

Annual Drinking Water Quality Report

2022



OUR DRINKING WATER IS RATED SUPERIOR  
CITY OF HOUSTON WATER IS RATED SUPERIOR  
MEETS OR EXCEEDS ALL FEDERAL (EPA) DRINKING WATER REQUIREMENTS

PWS ID # TX1010004

OUR DRINKING WATER IS REGULATED: This is your water quality report for January 1 to December 31, 2022. This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U. S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

**About this report:** TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact the City of Bellaire (713-662-8150).

## Your Drinking Water

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salt and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the City of Bellaire.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Bellaire is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### DEFINITIONS AND ABBREVIATIONS

**Maximum Contaminant Level (MCL):** The highest permissible level of a contaminant in drinking water. MCLs are set as close to the MCLG as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Picocuries per liter (pCi/L):** A measure of radioactivity.

**Parts per million (ppm):** The equivalent of milligrams per liter (mg/L) is analogous to 1 minute in 2 years.

**Parts per billion (ppb):** The equivalent of micrograms per liter (ug/L) is analogous to 1 minute in 32 years.

**NA:** Not Applicable.

Regulated Contaminants									
Inorganic Contaminants	YEAR	MCL	MCLG	HIGHEST LEVEL	RANGE	AVERAGE	RANGE	VIOLATION	LIKELY SOURCE OF CONTAMINATION
				DETECTED	Min - Max Level				
Arsenic (ppb)	2020	10	0	5.0	5.0 - 5.0	NA	NA	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
While your drinking water meets EPA standards for Arsenic, it does contain low levels of Arsenic. EPAs standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.									
Barium (ppm)	2022	2	2	0.16	0.16 - 0.16	0.050	0.0493 - 0.0512	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride (ppm)	2020	4	4	0.67	0.67 - 0.67	0.27	0.23 - 0.31	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate (ppm)	2022	10	10	0.15	0 - 0.15	0.22	0.16 - 0.27	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Cyanide (ppm)	2020	0.2	0.2	0.03	0 - 0.03	0.075	0.04 - 0.11	N	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
Turbidity	YEAR	MCL	LOWEST MONTHLY % <0.3 NTU			ANNUAL MAX		VIOLATION	LIKELY SOURCE OF CONTAMINATION
Turbidity (NTU)	2022	0.3	100%			0.34		N	Soil runoff.
Radioactive Contaminants	YEAR	MCL	MCLG	HIGHEST LEVEL	RANGE	AVERAGE	RANGE	VIOLATION	LIKELY SOURCE OF CONTAMINATION
Combined Radium 226-228 (pCi/L)	2017	5	0	1.39	1.39 - 1.39	NA	NA	N	Erosion of natural deposits.
Gross alpha (pCi/L)	2017	15	0	6.7	0 - 6.7	NA	NA	N	Erosion of natural deposits.
Uranium (ug/L)	2017	30	0	1.1	0 - 1.1	NA	NA	N	Erosion of natural deposits.
Synthetic Organic Contaminants	YEAR	MCL	MCLG	HIGHEST LEVEL	RANGE	AVERAGE	RANGE	VIOLATION	LIKELY SOURCE OF CONTAMINATION
Atrazine (ppb)	2022	3	3	0.22	0 - 0.22	0.23	0.2 - 0.23	N	Runoff from herbicide used on row crops.
Simazine (ppb)	2022	4	4	0.08	0 - 0.08	0.08	0.07 - 0.09	N	Herbicide runoff.
Disinfection By-products	YEAR	MCL	MCLG	HIGHEST LEVEL	RANGE	AVERAGE	RANGE	VIOLATION	LIKELY SOURCE OF CONTAMINATION
Total Trihalomethanes (TTHMs) (ppb)	2022	80	None	30	20.3 - 30.9	NA	NA	N	By-product of drinking water disinfection.
Haloacetic Acids (HAA5) (ppb)	2022	60	None	32	11.4 - 42	NA	NA	N	By-product of drinking water disinfection.
Disinfectant	YEAR	MRDL	MRDLG	AVERAGE	RANGE	AVERAGE	RANGE	VIOLATION	LIKELY SOURCE OF CONTAMINATION
Chloramines and Chlorine (ppm)	2022	4	4	1.58	1.26 - 1.88	NA	NA	N	Water additive used to control microbes.

Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort. We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated. The water was sampled and met all State requirements for safe potable drinking water. However, the DLQOR was not submitted in a timely manner to TCEQ.

Chlorine Violation	Disinfection Level Quarterly Operating Report (DLQOR)	Violation period 07/01/2022 - 09/30/2022	Total Coliform bacteria are used as indicators of microbial contamination of drinking water because testing for them is easy. While not disease causing organisms themselves, they are often found in association with other microbes that are capable of causing disease. Coliform bacteria are more hardy than many disease causing organisms; therefore, the absence from water is a good indication that the water is microbiologically safe for human consumption.						
<b>Total Coliform</b> Reported monthly tests found no Coliform bacteria.									
Lead and Copper	YEAR	MCLG	ACTION LEVEL	90th PERCENTILE	# of SITES OVER AL	AVERAGE	RANGE	VIOLATION	LIKELY SOURCE OF CONTAMINATION
Lead (ppb)	2021	0	15	0.5	0	0.0042	<0.0020 - 0.0064	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Chloroform (ppb)	2022	NA	NA	NA	NA	17	17 - 17	N	By-product of drinking water disinfection.
Bromodichloromethane (ppb)	2022	NA	NA	NA	NA	8.2	6.6 - 9.7	N	By-product of drinking water disinfection.
Dibromochloromethane (ppb)	2022	NA	NA	NA	NA	2.7	1.6 - 3.8	N	By-product of drinking water disinfection.

### Source of Drinking Water

**Where Do We Get Our Drinking Water?** The City of Bellaire provides 68% Surface Water supplied by the City of Houston's East Water Purification Plant 1 &2 and Southwest Repump, and 32% Ground Water from the Evangeline Aquifer located in Harris County. A Source Water Susceptibility Assessment for your drinking water sources is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies. Some of this source water assessment is available on Texas Drinking Water Watch at <http://www.tceq.state.tx.us/DWW/>. For more information on source water assessments and protection efforts at our system, please contact us.

The City of Bellaire purchases water from the City of Houston; City of Houston provides purchase surface water from the San Jacinto River through Lake Conroe and Lake Houston, and from the Trinity River through Lake Livingston.

**SPECIAL NOTICE:** You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk for infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available for the Safe Drinking Water Hotline (800-426-4791).